



## CLARIFICATIONS ON BID CITY OF VICTOR – DESIGN AND BUILD WALLACE PARK GAZEBO

In response to bidder questions, please review the following information prior to submitting your bids.

1. Alternative construction materials (other than heavy timber construction) will be accepted as long as the final appearance of the structure is historical.
2. We have not set a pre-bid walk through. You are welcome to visit the site: Wallace Park is located at 201 W. Victor Avenue—on the NW corner of Victor Ave and 2<sup>nd</sup> Street.
3. Please include in your bid the cost of dirt work (site grading and leveling). The City may be able to complete some or all of that work as in-kind, if bids.
4. We would like a 4” thick slab that matches the dimensions of the gazebo (approx.. 33’ X 33’).
5. We would like to have one light fixture in the middle of the gazebo sufficient to light the entire area at dusk plus four outlets up high (for plugging in Christmas lights). Light switch for overhead lighting should be at a height reached by a 5’ adult.
6. The city will supply the picnic tables.
7. Octagonal, square or rectangular construction will be accepted as long as it meets the historical details in conceptual design.
8. The City would like a line item bid for the following three elements: 1)concrete slab; 2)electrical cost and 3) design/construction, delivery and installation.
9. Power is available in both of the existing buildings (visitor’s center and public restroom) already located in the park.
10. The City does not have a list of contractors or bid holders.
11. The City is not requiring a bid bond, performance or payment bond.

Thank you for your interest in this project.

City of Victor

City Of Victor



500 Victor Ave.  
P.O. Box 86  
Victor, CO 80860



P 719.689.2284  
F 719.689.2703  
cityofvictor.com