

## Manual J Criteria Victor, Colorado

	<b>Cripple Creek and Victor</b>
<b>ELEVATION</b>	9600
<b>LATITUDE</b>	38 North
<b>WINTER HEATING</b>	-10
<b>SUMMER COOLING</b>	80
<b>ALTITUDE CORRECTION FACTOR</b>	.71
<b>INDOOR DESIGN TEMP HEATING</b>	70
<b>INDOOR DESIGN TEMP COOLING</b>	75
<b>HEATING TEMP DIFFERENCE</b>	80
<b>COOLING TEMP DIFFERENCE</b>	5
<b>COINCIDENT WET BULB</b>	55
<b>DAILY RANGE</b>	High
<b>WINTER HUMIDITY</b>	30%
<b>SUMMER HUMIDITY</b>	50%