

Esta es información importante.
Si no la pueden leer, necesitan que
alguien se la traduzca.

City of Victor
PO Box 86
Victor, Colorado 80860

We are pleased to present to you this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. Please contact Kurt Yeater at 719-321-8873 with any questions or for public participation opportunities that may affect water quality.

2019 ANNUAL DRINKING WATER QUALITY REPORT



CITY OF
VICTOR

PWS ID# C00160700

All Drinking Water May Contain Contaminants

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting epa.gov/ground-water-and-drinking-water

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and microbiological contaminants call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Substances that Could be in Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants: viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants: salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides: may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- Radioactive contaminants: can be naturally occurring or be the result of oil and gas production and mining activities.
- Organic chemical contaminants: including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems (especially for pregnant women and young children). It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. If you are concerned about lead in your water, you may wish to have your water tested. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

Source Water Assessment and Protection (SWAP)

The Colorado Department of Public Health and Environment may have provided us with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit wqcd-compliance.com/ccr. The report is located under "Guidance: Source Water Assessment Reports". Search the table using 160700, VICTOR CITY OF, or by contacting KURT YEATER at 719-321-8873. The Source Water Assessment Report provides a screening-level evaluation of potential contamination that could occur. It **does not** mean that the contamination **has or will** occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Potential sources of contamination in our source water area are listed on the next page.

How can I learn more about our drinking water?

Please contact us to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Quality Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.

Our Water Sources

| Source | Source Type | Water Type | Potential Source(s) of Contamination |
|-------------------------|-------------|----------------------------------|--|
| CRIPPLE CREEK WELL NO 5 | Well | Groundwater UDI Surface Water | Deciduous forests, evergreen forests, septic tanks and road miles. |
| WEST BEAVER CREEK | Intake | Surface Water | |
| CRIPPLE CREEK WELL NO 2 | Well | Groundwater | |
| BISON RESERVOIR | Intake | Surface Water | |
| VICTOR RESER NO 2 | Intake | Surface Water | |

The City of Victor routinely monitors for contaminants in your drinking water according to Federal and State laws. The following tables show all detections found in the period of January 1 to December 31, 2019 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report. Note: Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section then no contaminants were detected in the last round of monitoring.

Disinfectants Sampled In the Distribution System

| Contaminant (Units) | Collection Date | Results | Number of Samples Below Level | Sample Size | TT Violation | MRDL | Likely Source of Contamination |
|---------------------|-----------------|--|-------------------------------|-------------|--------------|---------|---|
| Chlorine (ppm) | 12/2019 | Lowest period percentage of samples meeting TT requirement: 100% * | 0 | 2 | No | 4.0 ppm | Water additive used to control microbes |

*TT Requirement: At least 95% of samples per period (month or quarter) must be at least 0.2 ppm OR if sample size is less than 40 no more than 1 sample is below 0.2 ppm

Lead and Copper Sampled in the Distribution System

| Contaminant (Units) | Time Period | 90th Percentile | Sample Size | 90th Percentile AL | Sample Sites over AL | 90th Percentile AL Exceedance | Likely Source of Contamination |
|---------------------|--------------------------|-----------------|-------------|--------------------|----------------------|-------------------------------|--|
| Copper (ppm) | 09/10/2019 to 09/18/2019 | 0.04 | 5 | 1.3 | 0 | No | Corrosion of household plumbing systems; erosion of natural deposits |
| Lead (ppb) | 09/10/2019 to 09/18/2019 | 0.5 | 5 | 15 | 0 | No | Corrosion of household plumbing systems; erosion of natural deposits |

Disinfection Byproducts Sampled in the Distribution System

| Contaminant (Units) | Year | Average | Range | Sample Size | MCL | MCLG | Violation (Yes/No) | Likely Source of Contamination |
|-------------------------------------|------|---------|-----------|-------------|-----|------|--------------------|---|
| Haloacetic Acids (HAA5) (ppb) | 2019 | 28.43 | 19.2-36.1 | 4 | 60 | N/A | No | By-product of drinking water chlorination |
| TTHMs (Total Trihalomethanes) (ppb) | 2019 | 31.3 | 23.3-36.9 | 4 | 80 | N/A | No | By-product of drinking water chlorination |

Inorganic Contaminants Sampled at the Entry Point to the Distribution System

| Contaminant (Units) | Year | Average | Range of Levels Detected | Sample Size | MCL | MCLG | Violation (Yes/No) | Likely Source of Contamination |
|---------------------|------|---------|--------------------------|-------------|-----|------|--------------------|--|
| Barium (ppm) | 2019 | 0.01 | 0.01-0.01 | 1 | 2 | 2 | No | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Beryllium (ppb) | 2019 | 0.48 | 0.48-0.48 | 1 | 4 | 4 | No | Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries |
| Fluoride (ppm) | 2019 | 2.1 | 2.1-2.1 | 1 | 4 | 4 | No | Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories |
| Nitrate (ppm) | 2019 | 0.18 | 0.18-0.18 | 1 | 10 | 10 | No | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Nitrite (ppm) | 2019 | 0 | 0-0 | 1 | 1 | 1 | No | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |

Fluoride: This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 parts per million (ppm) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system has a fluoride concentration above 2 parts per million (ppm), but below 4 parts per million (ppm). Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine years of age should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.

Drinking water containing more than 4 parts per million (ppm) of fluoride (the Colorado Department of Public Health and Environment's drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4 parts per million (ppm) of fluoride, but we're required to notify you when we discover that the fluoride levels in your drinking water exceed 2 parts per million (ppm) because of this cosmetic dental problem.

For more information, please contact us. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at (1-877-8-NSF-HELP).

Summary of Turbidity Sampled at the Entry Point to the Distribution System

| Contaminant | Sample Date | Level Found | TT Requirement | TT Violation | Likely Source of Contamination |
|-------------|-------------|---|---|--------------|--------------------------------|
| Turbidity | May 2019 | Highest single measurement: 0.19 NTU | Maximum 0.5 NTU for any single measurement | No | Soil Runoff |
| Turbidity | Dec. 2019 | Lowest Monthly percentage of samples meeting TT requirements for our technology: 100% | In any month, at least 95% of the samples must be less than 0.1 NTU | No | Soil Runoff |

Secondary Contaminants*

| Contaminant (Units) | Year | Average | Range | Sample Size | Secondary Standard |
|---------------------|------|---------|-------|-------------|--------------------|
| Sodium (ppm) | 2019 | 17.9 | 17.9 | 17.9 | N/A |

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin, or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.

Health Based Violations

Maximum contaminant level (MCL) violations: Test results for this contaminant show that the level was too high for the time period shown. Please read the information shown below about potential health effects for vulnerable populations. This is likely the same violation we told you about in a past notice. We are evaluating, or we already completed an evaluation, to find the best way to reduce or remove the contaminant. If the solution will take an extended period of time, we will keep you updated with quarterly notices.

Treatment technique (TT) violations: We failed to complete an action that could affect water quality. Please read the information shown below about potential health effects for vulnerable populations. This is likely the same violation that we told you about in a past notice. We were required to meet a minimum operation/treatment standard, we were required to make upgrades to our system, or we were required to evaluate our system for potential sanitary defects, and we failed to do so in the time period shown below. If the solution will take an extended period of time, we will keep you updated with quarterly notices.

| Name | Description | Time Period | Health Effects | Compliance Value | TT Level or MCL |
|-----------------------|--|-------------------|--|------------------|-----------------|
| STORAGE TANK RULE | FAILURE TO INSPECT STORAGE TANK(S) AND/OR FAILURE TO CORRECT STORAGE TANK DEFECTS - F318 | 11/20/2019 - Open | May pose a risk to public health. | N/A | N/A |
| CROSS CONNECTION RULE | FAILURE TO MEET CROSS CONNECTION CONTROL AND/OR BACKFLOW PREVENTION REQUIREMENTS - M612 | 11/20/2019 - Open | We have an inadequate backflow prevention and cross-connection control program. Uncontrolled cross connections can lead to inadvertent contamination of the drinking water. This is due to one or more of the following: We have permitted an uncontrolled cross connection, AND/OR we failed to comply with the requirements for surveying our system for cross connections, AND/OR we failed to complete the testing requirements for backflow prevention devices or methods, AND/OR we failed to notify the State Health Dept. of a backflow contamination event. | N/A | N/A |

Non-Health Based Violations

These violations do not usually mean that there was a problem with the water quality. If there had been, we would have notified you immediately. We missed collecting a sample (water quality is unknown), we reported the sample result after the due date, or we did not complete a report/notice by the required date.

| Name | Description | Time Period |
|-----------------------|---|-------------------------|
| STORAGE TANK RULE | FAILURE TO MEET STORAGE TANK REQUIREMENTS - F330 | 11/20/2019 - 11/20/2019 |
| CROSS CONNECTION RULE | FAILURE TO MEET CROSS CONNECTION CONTROL AND/OR BACKFLOW PREVENTION REQUIREMENTS - M613 | 11/20/2019 - Open |
| CROSS CONNECTION RULE | FAILURE TO MEET CROSS CONNECTION CONTROL AND/OR BACKFLOW PREVENTION REQUIREMENTS - M610 | 11/20/2019 - Open |

• Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. •

The City of Victor is in the process of requiring all known Backflow devices to be tested by private certified BFCCC personnel. The City of Victor has also received a 120 day extension to bring the BFCCC program into compliance according to the CDPHE. This extension was issued on April 23, 2020 by the CDPHE. The City of Victor is working diligently to bring the BFCCC program into compliance.

The City of Victor has implemented the CDPHE Storage Tank Inspection Rule and is now in compliance with the rule.

Backflow and Cross-Connection

We have an inadequate backflow prevention and cross-connection control program. Uncontrolled cross connections can lead to inadvertent contamination of the drinking water.

We either have installed or permitted an uncontrolled cross-connection or we experienced a backflow contamination event.

Definitions

In the data tables, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:

Maximum Contaminant Level (MCL) – The highest level of a contaminant allowed in drinking water.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Health-Based – A violation of either a MCL or TT.

Non-Health-Based – A violation that is not a MCL or TT.

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Violation (No Abbreviation) – Failure to meet a Colorado Primary Drinking Water Regulation.

Formal Enforcement Action (No Abbreviation) – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.

Variance and Exemptions (V/E) – Department permission not to meet a MCL or treatment technique under certain conditions.

Gross Alpha (No Abbreviation) – Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.

Picocuries per liter (pCi/L) – Measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) – Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.

Compliance Value (No Abbreviation) – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90th Percentile, Running Annual Average (RAA) and Locational Running Annual Average (LRAA).

Average (x-bar) – Typical value.

Range (R) – Lowest value to the highest value.

Sample Size (n) – Number or count of values (i.e. number of water samples collected).

Parts per million = Milligrams per liter (ppm = mg/L) – One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion = Micrograms per liter (ppb = ug/L) – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Not Applicable (N/A) – Does not apply or not available.

Level 1 Assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.